

BUILDING SAFETY CERTIFICATE

This is to certify that the building of Rajeev Kore Bright Future Public School Sangli, situated at T.P. Scheme 2, Final Plot 75, Harbhat Road, Sangli - 416416 is inspected by me and Sectional Engineer P.W. Section, Sangli

The G+2 school building is in order for educational purpose under normal circumstances based on visual inspection by this office, However the safety of building with respect to R.C.C. design from the consultant appointed by the school management.

The Compliance for the following points should be made

- 1) Ramp should be constructed for disabled persons
- 2) The floors of toilet and washrooms should be fitted anti slip tiles in order to avoid untoward incidents.
- 4) The electrical switch panels should be enclosed with wooden/steel box & these should be accessible by trained person only.
- 5) The electrical wiring should be hidden or covered

This certificate is valid for three years from the date of issue.



Assistant Executive Engineer Class – I
P. W. Sub-Division, Sangli

Counter Signed



EXECUTIVE ENGINEER
P. W. Division, Miraj

No. DB/Building/ 027 /2022
Office of the Executive Engineer
P. W. Division, Miraj
Date : 25/01/2022